

**Addendum #2 to IFB #Re 011019
Parking Lot E Reconstruction &
Parking Lot F Addition
McHenry County College**

This Addendum is in response to the inquiries from potential bidders. This Addendum constitutes changes to the specifications as sent out in the original IFB and other pertinent information shared with all vendors. All changes and information listed on this Addendum should be considered as the official modifications to the specifications and should be included in your proposal with these in mind.

Please acknowledge your receipt of this addendum by attaching a signed copy of the addendum with your proposal response.

Received and acknowledged by: _____

-
1. We are looking at the specs, and see that there is an aluminum gate that is called for, but are unable to locate it on the plans. Can you direct me to where the gate is shown on the plans? **No gate proposed on the project.**
 2. Where is the aluminum fence shown on the plans? **Fence is shown on the site plan and is located between the retaining wall and sidewalk that parallels the parking lot.**
 3. **Plan changes have been made to demo, site and grading plans to reflect removal of the bituminous walking path and replaced with a concrete sidewalk. Also the storm sewer discharge point was revised to better tie into the existing grades. All plan changes have been clouded and a new schedule of pricing reflective of the above and below is attached to this RFI.**
 4. **Sheet E2 was revised to include the below:**
 - **ADD (1) handhole HH-1 for low voltage and REVISE empty conduit routing as shown.**
 - **ADD (2) additional empty conduits for future CCTV camera as shown.**
 - **REVISE empty conduits size for future CCTV camera as shown.**