

Addendum #3 to IFB #Re 011019
Parking Lot E Reconstruction &
Parking Lot F Addition
McHenry County College

This Addendum is in response to the inquiries from potential bidders. This Addendum constitutes changes to the specifications as sent out in the original IFB and other pertinent information shared with all vendors. All changes and information listed on this Addendum should be considered as the official modifications to the specifications and should be included in your proposal with these in mind.

Please acknowledge your receipt of this addendum by attaching a signed copy of the addendum with your proposal response.

Received and acknowledged by: _____

-
1. Geotechnical report noting existing pavement thicknesses has been uploaded to the College's website.
 2. Schedule of pricing has been updated to correct the quantity of aggregate respread from stockpile. Additionally, the earthwork import line item has been revised and changed to an export. Lastly the topsoil strip quantity has been revised.
 3. Existing bituminous pavement noted to be removed is not intended to be ground/reused and should be disposed of offsite.
 4. Bid alt added for 12" & 15" N12 ADS storm sewer pipe.