

**Addendum #2  
November 20, 2017**

**McHenry County College**

**Supply and Install Water Pump Station**

This addendum forms a part of the bidding documents and contract documents and modifies the original bidding documents dated November 10, 2017. Acknowledge receipt of this addendum in the proposal. **Failure to do so may subject the Bidder to disqualification.**

**PROJECT MANUAL**

Page 14, Paragraph 2.05.A:

- Delete “The minimum roof slope shall be ½”:12” and replace with the following:  
“The roof slope shall be 5/12.”

Page 15, Paragraph 2.09.A:

- Change “Three” to “Four”.

**INFORMATION/CLARIFICATION**

The following are questions from a manufacturer about the project documents. The responses follow in bold italics.

1. 1.1 page 4 – The contract should read “Supply Water Pump Station” not “Supply & Install”. Any references to install in the documents should be removed as a second contract will be issued for installation of the pump station.  
***This contract is for the cost to supply the equipment in order to select a manufacturer. The manufacturer chosen will be designed around in the upcoming water main extension project. Please disregard any reference to “Installation”.***
2. 2.9 Bid Bond page 6 – is a 10% Bid Bond required as we are only supplying equipment and not installation?  
***A bid bond will not be required, since this contract is for equipment selection.***
3. 4.8 Performance and Payment Bond page 9 - Is this required for the equipment supplier?  
***A Performance and Payment Bond is not necessary for this contract, since this contract is for equipment selection.***

4. 2.02 Page 13 – Item D-K are specifications of one specific manufacturer.  
***Manufacturer can build based on their standard design as long as they meet or exceed the specified R-value.***
  
5. The exterior of the building is specified as fabricated Steni Stone panel. Can a different exterior be used?  
***Bid the building with the specified Steni Stone panels. Other exteriors will not be allowed.***

This Addendum #2 **must** be attached and signed with your Proposal.

Received \_\_\_\_\_, 2017

Manufacturer \_\_\_\_\_